

Certificate No:

2851-CPR-0162

Certificate of Constancy of Performance

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Name of construction product: (For full product details and conditions of use refer to the attached appendix) T11CTSFx77T-O(FR LSZH-FRNC) BLACK, Coaxial Cable, Single Core 2.0 sqmm/14 AWG

Produced by:

U-Jin Cable Ind. Co., Ltd.

442-23, CheongYeon-ro, YeonDong-myeon, Sejong-si, 30068 South Korea

And produced in the manufacturing plant(s):

U-Jin Cable Ind. Co., Ltd.

442-23, CheongYeon-ro, YeonDong-myeon, Sejong-si, 30068 South Korea

The certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZZ of the standard

EN 50575:2014 + A1:2016 - Power, control and communication cables - Cables for general applications in construction works subject to reaction to fire requirements

under System 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product

This certificate was first issued on 01/11/2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Signed for and on behalf of BASEC Conformity Limited

Date: 01/11/2023

This Certificate and Schedule(s) remain the property of BASEC Conformity Limited and must be returned when required.

BCL-BSF360 Issue 2/A2047/Cert Issue No.1

Long Herry

This document contains 2 pages and its reproduction is allowed only in an integral form.

BASEC Conformity Ltd. Registered Address: The Black Church, St Mary's Place, Dublin, Ireland D07 P4AX. Registered in Ireland No. 617855 Tel: +353 1 893 4964 Email: compliance@basec.org.uk, Web: https://www.basecconformity.ie/



Notified Body No: 2851



Certificate No: **2851-CPR-0162**

Appendix to Certificate of Constancy of Performance

T11CTSFx77T-O(FR LSZH-FRNC) BLACK, Coaxial Cable, Single Core 2.0 sqmm/14 AWG

Cable Identification	Number of Cores	Conductor Size	Reaction to Fire Classification in accordance with EN 13501-6:2014
T11CTSFx77T-O(FR LSZH- FRNC) BLACK, Coaxial Cable	1	14 AWG	Cca-s1a-d2-a1

Intended use:

Supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke.

Signed for and on behalf of BASEC

Conformity Limited

Date: 01/11/2023

This Certificate and Schedule(s) remain the property of BASEC Conformity Limited and must be returned when required.

BCL-BSF360 Issue 2/A2047/Cert Issue No.1

Long Heartens

This document contains 2 pages and its reproduction is allowed only in an integral form.

BASEC Conformity Ltd. Registered Address: The Black Church, St Mary's Place, Dublin, Ireland D07 P4AX. Registered in Ireland No. 617855 Tel: +353 1 893 4964 Email: compliance@basec.org.uk, Web: https://www.basecconformity.ie/



Notified Body No: 2851